

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Certificate of conformity of the factory production control**0432-CPR-00133-01 (EN)**

Version 02

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

flue liners and connecting flue pipes

made of stainless steel: 1.4404 / 1.4571, 1.4301

"KS"*(for a detailed product description see annex 1 of this certificate)*

placed on the market under the name or trade mark of

Kominus Polska Sp. z o.o.Łęzkowice 112
32-015 Kłaj POLAND

and produced in the manufacturing plant(s)

Kominus Polska Sp. z o.o.Łęzkowice 112
PL-32-015 Kłaj POLAND

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 1856-2:2009under **system 2+** are applied and that**the factory production control is assessed to be in conformity
with the applicable requirements**

This certificate was first issued on 01.01.2015 and will remain valid until 31.07.2029 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 01.08.2024

by order


Dr. rer. nat. Krasch
Head of Certification Body

This Certificate consists of 1 page and 1 annex(es).

This Certificate replaces the Certificate no. 0432-CPR-00133-01
dated 08.07.2019, Version 01.*The original of this document was issued in German language.
In case of doubt only the German version is valid.*

Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

Vom Hersteller erklärte Eigenschaften für / Declared conditions by the manufacturer for:

	Art der Abgasanlage/ Leitung <i>type of chimney/ flue pipe</i>	Harmonisierte Norm <i>standard</i>	Produktbeschreibung <i>Product description</i>
01	"KS" Innenrohre <i>flue liners</i> Innenrohr / <i>inner pipe</i> : 1.4404 / 1.4571 Wanddicke / <i>wall thickness</i> : $\geq 0,5$ mm (-10 %)	EN 1856-2:2009	T450 – N1 – D – Vm – L50050 – G T450 – N1 – W – Vm – L50050 – O DN 80 - 500
02	"KS" Verbindungsstücke / <i>connecting flue pipes</i> Innenrohr / <i>inner pipe</i> : 1.4404 / 1.4571 Wanddicke / <i>wall thickness</i> : $\geq 0,5$ mm (-10 %)	EN 1856-2:2009	T450 – N1 – D – Vm – L50050 – G(XX)NM T450 – N1 – W – Vm – L50050 – O(XX)NM DN 80 - 500 Abstand zu brennbaren Bauteilen:/ <i>distance to combustibles</i> : NM: nicht gemessen, 3x Nenndurchm., mindestens 375 mm <i>NM: not measured, 3x nominal diameter</i> <i>, minimum of 375 mm</i>
03	"KS" Innenrohre / <i>flue liners</i> Innenrohr / <i>inner pipe</i> : 1.4301 Wanddicke / <i>wall thickness</i> : $\geq 0,5$ mm (-10 %)	EN 1856-2:2009	T450 – N1 – D – V2 – L20050 – G T450 – N1 – W – V2 – L20050 – O DN 80 - 500
04	"KS" Verbindungsstücke / <i>connecting flue pipes</i> Innenrohr / <i>inner pipe</i> : 1.4301 Wanddicke / <i>wall thickness</i> : $\geq 0,5$ mm (-10 %)	EN 1856-2:2009	T450 – N1 – O – V2 – L20050 – G(XX)NM T450 – N1 – W – V2 – L20050 – O(XX)NM DN 80 - 500 Abstand zu brennbaren Bauteilen:/ <i>distance to combustibles</i> : NM: nicht gemessen, 3x Nenndurchm., mindestens 375 mm <i>NM: not measured, 3x nominal diameter</i> <i>, minimum of 375 mm</i>